



RMKu-E

**Product description:**

RMKu-E is a polyolefin push-fit coupling, in opaque, non-flame propagating.

This coupling is used for all zero halogen corrugated conduits.



VDE 0605
DIN EN 61386-22



Cat. No.:	Type	Outside Ø mm	Content	PU	Weight PU/kg	Overall length mm
259 30 016	16	17,3	50	PCS	0,050	56,0
259 30 020	20	21,6	100	PCS	0,200	56,0
259 30 025	25	26,7	100	PCS	0,500	75,0
259 30 032	32	33,7	50	PCS	0,350	75,0
259 30 040	40	41,8	25	PCS	0,300	102,0
259 30 050	50	51,5	10	PCS	0,180	102,0

Standardisation

EN 61386-1:2009 Conduit systems for cable management - Part 1: General requirements / Source: Official Journal of the European Union of 16 May 2014 / Applied in full

EN 61386-22:2011 Conduit systems for cable management - Part 22: Particular requirements - Pliable conduit systems / Source: Official Journal of the European Union of 16 May 2014 / Applied in full

All dimensions without tolerances are for information only.



RMKu-E

Material properties		Fields of application	
Zero halogen	DIN VDE V 0604-2-100	on plaster	• machines
Low smoke	DIN EN 61034-2	under plaster	• hot asphalt
Non-flame propagating	DIN EN 61386-1	• on wood	• under screed
UV-resistant	DIN 53387	underground installation	• prefabricated construction
Highspeed		in concrete	• outdoor

Chemical properties	
Resistant to	hydrochloric acid emissions, sulphuric acid emissions, liquid ammonia, gaseous ammonia, gasoline, beer, diesel fuel, aqueous fertiliser salt, photographic developer, vinegar (wine vinegar), anti-freeze, fruit juices, aqueous uric acid, fuel oil, sea water, methanol, milk, mineral oil, vegetable and animal oils, paraffin, gaseous propane, hydrochloric acid, sulfuric acid, detergent
Limitedly resistant to	benzene, gaseous dry chlorine, nitric acid, terpentine
Not resistant to	-

Risk analysis

The product has been manufactured and tested according to the harmonized standards 61386-1 and 61386-22 in the sense of harmonization legislation of the EU. All safety-relevant tests have been adhered to. This product poses no further risk.

Hotline

Since technical developments cannot be foreseen, electrical installations should provide the possibility to be expanded at any time.

Information can be obtained from our technical consultants at +49 9525 88-8123

